

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **BLUE RIDGE FIBERBOARD, INC.**
250 Celotex Drive, Danville, VA 24541

Category: Construction Material - Ceiling & Wall Panels
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *private office setting (as 2 walls or as ceiling panels)*
California Dept. of Public Health Standard Method v1.2 *classroom setting (as 4 walls or as ceiling panels)*

*Conforms With: Criteria of MAS Certified Green® Program
LEED v4.1 ID+C, BD+C *low-emitting materials*
LEED TVOC Emissions at 14-days *low-emitting materials*
CHPS 2019 Core Criteria 3.0 EQ C6.1.6 *0.5 mg/m³ or less ceiling & wall systems*

Certified Products: Acoustical Panel: STRUCTODEK® HD
SoundStop Acoustical Panel product tested as representative exemplar of product listed above.

Test Date: May 22, 2024 Report No.:2400261R1 Certificate No.: MAS2400261R1-03

Valid: May 2024 to May 2025



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. 30024 · 770-866-3200 · <http://www.mascertifiedgreen.com/>